



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2433

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Alden South Hills*

Address: *5492 Youngridge Dr.*
 Pittsburgh, PA 15236

Date: 8/6/25
Time: 11:51 AM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Pool*

Date: 8/8/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25 3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	8/6/25 11:51 AM	ZS	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/6/25 11:51 AM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25 11:51 AM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2433

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Alden South Hills*

Address: *5492 Youngridge Dr.*
 Pittsburgh, PA 15236

Date: 8/6/25
Time: 11:51 AM
Method: Grab

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Pool*

Date: 8/8/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25 3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	8/6/25 11:51 AM	ZS	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/6/25 11:51 AM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25 11:51 AM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor