



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2000

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: 1400 Main @ Southpointe
Address: 1400 Main St.
Canonsburg, PA 15317

Sample Collection

Date: 5/28/25
Time: 11:36 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool
Date: 5/31/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25 10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25 10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25 5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/28/25 11:36 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25 11:36 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25 11:36 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2000

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *1400 Main @ Southpointe*
Address: *1400 Main St.*
Canonsburg, PA 15317

Date: *5/28/25*
Time: *11:36 AM*
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Pool*

Date: *5/31/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25 10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25 10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25 5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/28/25 11:36 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25 11:36 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25 11:36 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor