



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 059

Customer

Facility Name: Colfax Elementary
Address: 2332 Beechwood Blvd.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 8/11/25
Time: 10:36 AM
Method: Grab

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	8/12/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	8/12/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	A	8/11/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.2 SU	C	8/11/25	10:36 AM	SL	DPD
Chlorine:	3.0 mg/l	A	8/11/25	10:36 AM	SL	DPD
Turbidity:	1 NTU	A	8/11/25	10:36 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 059

Customer

Facility Name: Colfax Elementary
Address: 2332 Beechwood Blvd.
Pittsburgh, PA 15217

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 8/11/25
Time: 10:36 AM
Method: Grab

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	8/12/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	8/12/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	A	8/11/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.2 SU	C	8/11/25	10:36 AM	SL	DPD
Chlorine:	3.0 mg/l	A	8/11/25	10:36 AM	SL	DPD
Turbidity:	1 NTU	A	8/11/25	10:36 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor