



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2319

Customer

Facility Name: Liberty Hills
Address: 100 Liberty Lane
Freedom, PA 15042

Sample Collection

Date: 5/27/25
Time: 12:21 PM
Method: Grab

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/27/25 | 12:21 PM | ZR | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 12:21 PM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 12:21 PM | ZR | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2319

Customer

Facility Name: Liberty Hills
Address: 100 Liberty Lane
Freedom, PA 15042

Sample Collection

Date: 5/27/25
Time: 12:21 PM
Method: Grab

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/27/25 | 12:21 PM | ZR | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 12:21 PM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 12:21 PM | ZR | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)