

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 109

<u>Customer</u> Facility Name:

Gateway High School

Address:

3000 Gateway Campus Blvd.

Monroeville, PA 15146

Matrix:

Recreational Water

Source Type: Shallow End

Sample Collection

Date: 8/19/25

Date: Time:

12:09 PM

Method: Grab

Sample Final Analysis

Date: Time:

8/22/25 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/19/25	12:09 PM	EH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/19/25	12:09 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	12:09 PM	EH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor