



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 2767**

**Customer**

Facility Name: Foundmore  
Address: 300 Hillview Dr.  
Ross Twp., PA 15237

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/29/25  
Time: 8:41 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/1/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/29/25	8:41 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/29/25	8:41 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	8:41 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-13**

**Lab# 2767**

**Customer**

Facility Name: Foundmore  
Address: 300 Hillview Dr.  
Ross Twp., PA 15237

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/29/25  
Time: 8:41 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/1/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/29/25	8:41 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/29/25	8:41 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	8:41 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor