



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 074

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Dr.
West Homestead, PA 15120

Sample Collection

Date: 10/20/25
Time: 7:30 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 10/23/25
Time: 10:00 AM
Analyst: AS

Source Type: Spa

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/21/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/21/25	9:30 AM	SL	SM 9222B
Standard plate count:	20/ml	200/ml	10/20/25	4:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/21/25	10:30 AM	JC	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/20/25	7:30 AM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/20/25	7:30 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/20/25	7:30 AM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor