



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2252**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Hidden Valley Manor*  
  
*Address:*            *2774 Bingham Dr.*  
                              *Upper St. Clair, PA 15241*

*Date:*                  *6/24/25*  
*Time:*                *3:27 PM*  
*Method:*             *Grab*

**Sample Final Analysis**

*Matrix:*                *Recreational Water*  
  
*Source Type:*        *Pool*

*Date:*                  *6/27/25*  
*Time:*                *9:20 AM*  
*Analyst:*              *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:40 PM	AS	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	3:27 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/24/25	3:27 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	3:27 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2252**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date:*                6/24/25  
*Time:*             3:27 PM  
*Method:*          Grab

**Sample Final Analysis**

*Date:*                6/27/25  
*Time:*             9:20 AM  
*Analyst:*           AS

*Facility Name:*      *Hidden Valley Manor*  
  
*Address:*            *2774 Bingham Dr.*  
*Upper St. Clair, PA 15241*

*Matrix:*              *Recreational Water*  
  
*Source Type:*       *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	3:27 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/24/25	3:27 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	3:27 PM	AF	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor