



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 203

Customer

Facility Name: L.A. Fitness Greensburg

Address: 3000 Lincoln Place
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/15/25

Time: 9:38 AM

Method: Grab

Sample Final Analysis

Date: 7/18/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/16/25 10:10 AM	AH	SM 9222G
-------------------	--------	--------	------------------	----	----------

Total coliforms:	0/100mls	2/100mls	7/16/25 10:10 AM	AH	SM 9222B
------------------	----------	----------	------------------	----	----------

Standard plate count:	0/ml	200/ml	7/15/25 4:00 PM	AH	SM 9215B
-----------------------	------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/16/25 11:50 AM	AH	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	7/15/25 9:38 AM	JC	DPD
-----	--------	--------------	-----------------	----	-----

Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25 9:38 AM	JC	DPD
-----------	----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/15/25 9:38 AM	JC	Visual
------------	-------	-----------	-----------------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 203

Customer

Facility Name: L.A. Fitness Greensburg

Address: 3000 Lincoln Place
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/15/25

Time: 9:38 AM

Method: Grab

Sample Final Analysis

Date: 7/18/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/16/25	10:10 AM	AH	SM 9222G
-------------------	--------	--------	---------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	7/16/25	10:10 AM	AH	SM 9222B
------------------	----------	----------	---------	----------	----	----------

Standard plate count:	0/ml	200/ml	7/15/25	4:00 PM	AH	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/16/25	11:50 AM	AH	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	7/15/25	9:38 AM	JC	DPD
-----	--------	--------------	---------	---------	----	-----

Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25	9:38 AM	JC	DPD
-----------	----------	----------------	---------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	7/15/25	9:38 AM	JC	Visual
------------	-------	-----------	---------	---------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor