

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 13

Lab ID No. 02-04041

Lab# 2392

7/25/25

Customer Sample Collection

7/22/25 Facility Name: Park Swim Club Date: Time: 1:25 PM Address: College Park Dr. Method: Grab

Monroeville, PA 15146

Sample Final Analysis Matrix: Recreational Water Date:

10:00 AM Time: Source Type: Deep End Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/23/25 10:00 AM SL SM 9222G Total coliforms: 0/100mls SL 2/100mls 7/23/25 10:00 AM SM 9222B Standard plate count: 0/ml 200/ml 7/22/25 3:40 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	1:25 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:25 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:25 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 13

Lab ID No. 02-04041

Lab# 2392

7/25/25

Customer Sample Collection

7/22/25 Facility Name: Park Swim Club Date: Time: 1:25 PM Address: College Park Dr. Method: Grab

Monroeville, PA 15146

Sample Final Analysis Matrix: Recreational Water Date:

10:00 AM Time: Source Type: Deep End Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/23/25 10:00 AM SL SM 9222G Total coliforms: 0/100mls SL 2/100mls 7/23/25 10:00 AM SM 9222B Standard plate count: 0/ml 200/ml 7/22/25 3:40 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	1:25 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	1:25 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	1:25 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith Andre Smith, Lead Supervisor