Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 060

Customer

Facility Name:	*Comfort Inn*
Address:	*699 Rodi Road*
	Pittsburgh, PA 15235
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/9/25*
Time:	8:55 AM
Method:	*Grab*

Sample Final Analysis

Date:	*6/12/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/9/25	2:38 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	8:55 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/9/25	8:55 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	8:55 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 060

Customer		**Sample Collection**	
Facility Name:	*Comfort Inn*	*Date:*	*6/9/25*
		Time:	8:55 AM
Address:	*699 Rodi Road*	*Method:*	*Grab*
	Pittsburgh, PA 15235		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/12/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	6/9/25	2:38 PM	AH	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	8:55 AM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/9/25	8:55 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	8:55 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor