



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2035

Customer

Facility Name: *Bellevue Borough*
Address: *322 Bellevue Rd.*
Pittsburgh, PA 15202

Sample Collection

Date: *7/22/25*
Time: *9:22 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *7/25/25*
Time: *10:00 AM*
Analyst: *1/0/00*

Source Type: *Baby Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	9:22 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:22 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:22 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2035

Customer

Facility Name: *Bellevue Borough*
Address: *322 Bellevue Rd.*
Pittsburgh, PA 15202

Sample Collection

Date: *7/22/25*
Time: *9:22 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *7/25/25*
Time: *10:00 AM*
Analyst: *1/0/00*

Source Type: *Baby Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	9:22 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:22 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:22 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor