

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2294

Customer

Facility Name: Jamestown Condominiums

Address:

500 Alder Rd.

Pittsburgh, PA 15216

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Date: Time:

1:01 PM

Method: Grab

Sample Final Analysis

Date:

7/3/25 9:30 AM

Time: Analyst:

AS

Accredited Analysis Results		Reporting limit	Incubation	n Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	ı	Date/Time	Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	6/30/25	1:01 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/25	1:01 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	1:01 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2294

Customer

Facility Name: Jamestown Condominiums

Address:

500 Alder Rd.

Pittsburgh, PA 15216

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Date: Time:

1:01 PM

Method: Grab

Sample Final Analysis

Date:

7/3/25 9:30 AM

Time: Analyst:

AS

Accredited Analysis Results		Reporting limit	Incubation	n Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	ı	Date/Time	Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	6/30/25	1:01 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/25	1:01 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	1:01 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor