



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 441

Customer

Facility Name: Hampton Inn
Address: N. Rachel Dr
New Stanton, PA 15672

Sample Collection

Date: 5/27/25
Time: 8:18 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 4:20 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/27/25 | 8:18 AM | JC | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 8:18 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 8:18 AM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 441

Customer

Facility Name: Hampton Inn
Address: N. Rachel Dr
New Stanton, PA 15672

Sample Collection

Date: 5/27/25
Time: 8:18 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 4:20 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 5/27/25 | 8:18 AM | JC | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 8:18 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 8:18 AM | JC | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor