



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2373

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Nob Hill	Date:	6/9/25
Address:	3000 Swallow Hill Rd. Pittsburgh, PA 15220	Time:	12:07 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<b><u>Sample Final Analysis</u></b>	
Matrix:	Recreational Water	Date:	6/12/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/10/25	10:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:35 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:07 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:07 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:07 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2373

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Nob Hill	Date:	6/9/25
Address:	3000 Swallow Hill Rd. Pittsburgh, PA 15220	Time:	12:07 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<b><u>Sample Final Analysis</u></b>	
Matrix:	Recreational Water	Date:	6/12/25
Source Type:	Pool	Time:	9:30 AM
		Analyst:	AS

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/10/25	10:35 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:35 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	12:07 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:07 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:07 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor