



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2087

Customer

Facility Name: Chanticleer Condominiums

Address: 53 Highland Rd.
Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25

Time: 9:45 AM

Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	9:45 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25	9:45 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	9:45 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2087

Customer

Facility Name: Chanticleer Condominiums

Address: 53 Highland Rd.
Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25

Time: 9:45 AM

Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	9:45 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25	9:45 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	9:45 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor