

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

S-10

Lab ID No. 02-04041

Lab# 259

Laboratory Analysis Report

Sample Collection **Customer** Facility Name: Providence Pointe Date: 7/21/25 Time: 11:50 AM Address: 301 Kane Boulevard Method: Grab Pittsburgh, PA 15243 Sample Final Analysis Matrix: Recreational Water Date: 7/24/25 Time: 10:00 AM Source Type: Spa Analyst: AS **Accredited Analysis** Results **Reporting limit** Incubation Date/Time **Analyst** Method Escherichia Coli: 11:30 AM SM 9222G Absent Absent 7/22/25 AΗ Total coliforms: 0/100mls 2/100mls AΗ 7/22/25 11:30 AM SM 9222B Standard plate count: 0/ml 200/ml 7/21/25 5:30 PM SL SM 9215B **Additional Analysis** Reporting limit Results **Analyst** Method **Incubation Date/Time**

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	11:50 AM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/21/25	11:50 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	11:50 AM	CW	Visual

7/22/25

2/100mls

Sample comments

Fecal Streptococcus

0/100mls

andre Smith

12:00 AM

AΗ

SM 9230C

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

S-10

Lab ID No. 02-04041

Lab# 259

Laboratory Analysis Report

Sample Collection **Customer** Facility Name: Providence Pointe Date: 7/21/25 Time: 11:50 AM Address: 301 Kane Boulevard Method: Grab Pittsburgh, PA 15243 Sample Final Analysis Matrix: Recreational Water Date: 7/24/25 Time: 10:00 AM Source Type: Spa Analyst: AS **Accredited Analysis** Results **Reporting limit** Incubation Date/Time **Analyst** Method Escherichia Coli: 11:30 AM SM 9222G Absent Absent 7/22/25 AΗ Total coliforms: 0/100mls 2/100mls AΗ 7/22/25 11:30 AM SM 9222B Standard plate count: 0/ml 200/ml 7/21/25 5:30 PM SL SM 9215B **Additional Analysis** Reporting limit Results **Analyst** Method **Incubation Date/Time**

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	11:50 AM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/21/25	11:50 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	11:50 AM	CW	Visual

7/22/25

2/100mls

Sample comments

Fecal Streptococcus

0/100mls

andre Smith

12:00 AM

AΗ

SM 9230C

(When exceeding reporting limit pool or spa is unfit)