



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2391

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Park Place

Date: 6/3/25

Time: 12:14 PM

Address: 1700 Patrick Pl
South Park, PA 15129

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/6/25

Time: 9:30 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	12:00 AM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/3/25	12:14 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/3/25	12:14 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	12:14 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2391

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Park Place

Date: 6/3/25

Time: 12:14 PM

Address: 1700 Patrick Pl
South Park, PA 15129

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/6/25

Time: 9:30 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	12:00 AM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/3/25	12:14 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/3/25	12:14 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	12:14 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor