

Customer

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2635

Sample Collection

Facility Name: Village Cranberry Woods Apt. Date: 5/28/25 Time: 11:32 AM Address: 5001 Pendleton Way Method: Grab Cranberry, PA 16066 Sample Final Analysis Matrix: Recreational Water Date: 5/31/25 Time: 9:30 AM Source Type: Spa Analyst: AS **Accredited Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: 11:30 AM Absent Absent 5/29/25 AΗ SM 9222G Total coliforms: 0/100mls 2/100mls SM 9222B 5/29/25 11:30 AM AΗ Standard plate count: 200/ml 200/ml 5/28/25 6:25 PM SL SM 9215B **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time**

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:32 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:32 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:32 AM	ZR	Visual

5/29/25

2/100mls

Sample comments

Fecal Streptococcus

0/100mls

andre Smith

11:50 AM

AH

SM 9230C

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Customer

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2635

Sample Collection

Facility Name: Village Cranberry Woods Apt. Date: 5/28/25 Time: 11:32 AM Address: 5001 Pendleton Way Method: Grab Cranberry, PA 16066 Sample Final Analysis Matrix: Recreational Water Date: 5/31/25 Time: 9:30 AM Source Type: Spa Analyst: AS **Accredited Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: 11:30 AM Absent Absent 5/29/25 AΗ SM 9222G Total coliforms: 0/100mls 2/100mls SM 9222B 5/29/25 11:30 AM AΗ Standard plate count: 200/ml 200/ml 5/28/25 6:25 PM SL SM 9215B **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time**

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	11:32 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:32 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:32 AM	ZR	Visual

5/29/25

2/100mls

Sample comments

Fecal Streptococcus

0/100mls

andre Smith

11:50 AM

AH

SM 9230C

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor