



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2331

**Customer**

Facility Name: Magee  
Address: 745 Greenfield Ave.  
Pittsburgh, PA 15217

**Sample Collection**

Date: 6/17/25  
Time: 10:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/20/25  
Time: 9:00 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	10:45 AM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	6/17/25	10:45 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	10:45 AM	WB	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2331

**Customer**

Facility Name: Magee  
Address: 745 Greenfield Ave.  
Pittsburgh, PA 15217

**Sample Collection**

Date: 6/17/25  
Time: 10:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/20/25  
Time: 9:00 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	10:45 AM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	6/17/25	10:45 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	10:45 AM	WB	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor