



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 305

Customer

Facility Name: University of Pittsburgh

Address: 3501 Allequippa St.
Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Lg Pool Middle 2

Sample Collection

Date: 10/14/25

Time: 10:56 AM

Method: Grab

Sample Final Analysis

Date: 10/17/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/15/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/15/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/14/25	2:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/14/25	10:56 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/14/25	10:56 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/14/25	10:56 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor