



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 039**

**Customer**

**Facility Name:** Carlynton High School

**Address:** 435 Kings Hwy.  
Carnegie, PA 15106

**Matrix:** Recreational Water

**Source Type:** Shallow End

**Sample Collection**

**Date:** 10/6/25

**Time:** 9:14 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 10/9/25

**Time:** 11:00 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/7/25	10:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/25	10:20 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	10/6/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/6/25	9:14 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/6/25	9:14 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/25	9:14 AM	SL	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor