

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2273

 Customer
 Sample Collection

 Facility Name:
 Hosanna Camp
 Date: 7/7/25

 Time:
 1:02 PM

 Address:
 400 Sherwood Rd
 Method: Grab

Pittsburgh, PA 15221

Matrix: Recreational Water Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM

Source Type: Deep End Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	АН	SM 9222B
Standard plate count:	80/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	7/7/25	1:02 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:02 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:02 PM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2273

 Customer
 Sample Collection

 Facility Name:
 Hosanna Camp
 Date: 7/7/25

 Time:
 1:02 PM

 Address:
 400 Sherwood Rd
 Method: Grab

Pittsburgh, PA 15221

Matrix: Recreational Water Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM

Source Type: Deep End Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	АН	SM 9222B
Standard plate count:	80/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	7/7/25	1:02 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:02 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:02 PM	EH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)