



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2287**

**Customer**

**Facility Name:** *Ingomar North Swim Club*

**Address:** *460 Olive Street  
Pittsburgh, PA 15237*

**Matrix:** *Recreational Water*

**Source Type:** *Baby Pool*

**Sample Collection**

**Date:** *7/15/25*

**Time:** *2:10 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/18/25*

**Time:** *9:30 AM*

**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/16/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	11:20 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/15/25	5:20 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	2:10 PM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25	2:10 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	2:10 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2287**

**Customer**

**Facility Name:** *Ingomar North Swim Club*

**Address:** *460 Olive Street  
Pittsburgh, PA 15237*

**Matrix:** *Recreational Water*

**Source Type:** *Baby Pool*

**Sample Collection**

**Date:** *7/15/25*

**Time:** *2:10 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/18/25*

**Time:** *9:30 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	11:20 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/15/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	2:10 PM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25	2:10 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	2:10 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor