C-11



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab# 056

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Club Pittsburgh Date: 5/28/25

Address: Time: 10:20 AM Method: Grab

Pittsburgh, PA 15222

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Source Type: Spa Time: 9:30 AM
Analyst: AS

Accredited Analysis Reporting limit Results **Analyst** Method Incubation Date/Time Escherichia Coli: 10:40 AM EΒ SM 9222G Absent Absent 5/29/25 Total coliforms: 0/100mls 2/100mls 5/29/25 10:40 AM EΒ SM 9222B Standard plate count: 200/ml 6:25 PM 0/ml 5/28/25 AΗ SM 9215B Reporting limit **Additional Analysis** Results **Analyst** Method Incubation Date/Time Fecal Streptococcus 0/100mls 2/100mls 5/29/25 11:50 AM AΗ SM 9230C

Reporting limit Date/Time Field Analysis Results Analyst Method 7.4 SU 7.2 - 7.8 SU DPD pH: 5/28/25 10:20 AM LM Chlorine: DPD 1.0 mg/l 1.0 - 5.0 mg/l 5/28/25 10:20 AM LM

5/28/25

1 - 2 NTU

Sample comments

Turbidity:

andre Smith

10:20 AM

LM

Visual

(When exceeding reporting limit pool or spa is unfit)

1 NTU

Andre Smith, Lead Supervisor

C-11



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab# 056

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Club Pittsburgh Date: 5/28/25

Address: Time: 10:20 AM Method: Grab

Pittsburgh, PA 15222

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Source Type: Spa Time: 9:30 AM
Analyst: AS

Accredited Analysis Reporting limit Results **Analyst** Method Incubation Date/Time Escherichia Coli: 10:40 AM EΒ SM 9222G Absent Absent 5/29/25 Total coliforms: 0/100mls 2/100mls 5/29/25 10:40 AM EΒ SM 9222B Standard plate count: 200/ml 6:25 PM 0/ml 5/28/25 AΗ SM 9215B Reporting limit **Additional Analysis** Results **Analyst** Method Incubation Date/Time Fecal Streptococcus 0/100mls 2/100mls 5/29/25 11:50 AM AΗ SM 9230C

Reporting limit Date/Time Field Analysis Results Analyst Method 7.4 SU 7.2 - 7.8 SU DPD pH: 5/28/25 10:20 AM LM Chlorine: DPD 1.0 mg/l 1.0 - 5.0 mg/l 5/28/25 10:20 AM LM

5/28/25

1 - 2 NTU

Sample comments

Turbidity:

andre Smith

10:20 AM

LM

Visual

(When exceeding reporting limit pool or spa is unfit)

1 NTU

Andre Smith, Lead Supervisor