



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 336

Customer

Facility Name: Westinghouse H.S.

Address: 1101 Murtland Ave
Pittsburgh, PA 15208

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 2/16/26
Time: 9:56 AM
Method: Grab

Sample Final Analysis

Date: 2/18/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	2/17/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	2/17/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	2/16/26	5:08 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	2/16/26	9:56 AM	MM	DPD
Chlorine:	2.0 mg/l	B	2/16/26	9:56 AM	MM	DPD
Turbidity:	1 NTU	A	2/16/26	9:56 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)