



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 469**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *137 Blair St.*  
*Greensburg, PA 15601*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *6/3/25*  
**Time:** *9:13 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/6/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|---------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 6/4/25                      | 9:30 AM | AH             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 6/4/25                      | 9:30 AM | AH             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 6/3/25                      | 3:50 PM | AH             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|---------|----------------|---------------|
| pH:                   | 7.8 SU         | 7.2 - 7.8 SU           | 6/3/25           | 9:13 AM | JC             | DPD           |
| Chlorine:             | 10.0 mg/l      | 1.0 - 5.0 mg/l         | 6/3/25           | 9:13 AM | JC             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 6/3/25           | 9:13 AM | JC             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 469**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *137 Blair St.*  
*Greensburg, PA 15601*

**Sample Collection**

**Date:** *6/3/25*  
**Time:** *9:13 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

**Sample Final Analysis**

**Date:** *6/6/25*  
**Time:** *9:30 AM*  
**Analyst:** *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/4/25               | 9:30 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/4/25               | 9:30 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/3/25               | 3:50 PM | AH      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|-----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU    | 7.2 - 7.8 SU    | 6/3/25    | 9:13 AM | JC      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 6/3/25    | 9:13 AM | JC      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 6/3/25    | 9:13 AM | JC      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor