



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-1**

**Lab# 042**

**Customer**

**Facility Name:** Carnegie Mellon  
**Address:** 5000 Forbes Ave.  
Pittsburgh, PA 15213

**Matrix:** Recreational Water

**Source Type:** Lap pool Deep

**Sample Collection**

**Date:** 1/19/26  
**Time:** 8:50 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 1/22/26  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/20/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/20/26	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	1/19/26	3:16 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/19/26	8:50 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/19/26	8:50 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/19/26	8:50 AM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor