



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 279

Customer

Facility Name: Sheraton Inn
Address: 300 W Station Sq. Dr.
Pittsburgh, PA 15219
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/19/25
Time: 1:25 PM
Method: Grab

Sample Final Analysis

Date: 8/22/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	11:00 AM	EB
Total coliforms:	0/100mls	2/100mls	8/20/25	11:00 AM	EB
Standard plate count:	0/ml	200/ml	8/19/25	5:00 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/19/25	1:25 PM	LM
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/19/25	1:25 PM	LM
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	1:25 PM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor