



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 353

Customer

Facility Name: YMCA - Butler

Address: 339 North Washington St.
Butler, PA 16001

Matrix: Recreational Water

Source Type: Large Pool

Sample Collection

Date: 8/4/25

Time: 12:10 PM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	12:10 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:10 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:10 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 353

Customer

Facility Name: YMCA - Butler

Address: 339 North Washington St.
Butler, PA 16001

Matrix: Recreational Water

Source Type: Large Pool

Sample Collection

Date: 8/4/25

Time: 12:10 PM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	12:10 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:10 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:10 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor