



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 327

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Washington & Jefferson	Date:	1/20/26			
Address:	60 S. Lincoln St. Washington, PA 15301	Time:	8:29 AM			
Matrix:	Recreational Water	Method:	Grab			
Source Type:	Lap Pool	<u>Sample Final Analysis</u>				
		Date:	1/23/26			
		Time:	10:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	1/21/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/21/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/20/26	4:27 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	1/20/26	8:29 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	1/20/26	8:29 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/20/26	8:29 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)