



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 120

Customer

Facility Name: Wingate
Address: 210 Executive Drive
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 8/18/25
Time: 11:46 AM
Method: Grab

Sample Final Analysis

Date: 8/21/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 8/19/25 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/19/25 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/18/25 4:20 PM | EB | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 8/19/25 11:00 AM | EB | SM 9230C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|------------------|----|--------|
| pH: | 7.3 SU | 7.2 - 7.8 SU | 8/18/25 11:46 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/18/25 11:46 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/18/25 11:46 AM | ZR | Visual |

Sample comments

Anaë Smith

(When exceeding reporting limit pool or spa is unfit)