



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 193**

**Customer**

Facility Name: *Keystone Oaks High School*

Address: *1000 Kelton Ave.*  
*Pittsburgh, PA 15216*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

**Sample Collection**

Date: *10/21/25*

Time: *9:48 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *10/24/25*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/22/25 10:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/22/25 10:10 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/21/25 5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/21/25 9:48 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/21/25 9:48 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/21/25 9:48 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor