

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-12

Lab ID No. 02-04041

Lab# 016

8/28/25

9:00 AM

Customer

Facility Name:

Baldwin H.S.

Address:

4653 Clairton Boulevard Pittsburgh, PA 15236

Matrix:

Source Type:

Recreational Water

Deep End

Sample Collection

Date: 8/25/25 Time: 9:55 AM

Method: Grab

Sample Final Analysis

Date: Time:

Analyst: AS

Accredited Analysis Results Reporting limit Incubation Date/Time Analyst Method Escherichia Coli: Absent Absent 8/26/25 8:20 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 8:20 AM AS SM 9222B 8/26/25 Standard plate count: 150/ml 200/ml 8/25/25 3:50 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	8/25/25	9:55 AM	BL	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/25/25	9:55 AM	BL	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	9:55 AM	BL	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)