



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
PPS

Lab# 004

Customer

Facility Name: *Allderdice H.S.*

Address: *2409 Shady Ave.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *6/3/25*
Time: *9:20 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/6/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	6/4/25 11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	6/4/25 11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	A	6/3/25 5:15 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.4 SU	A	6/3/25 9:20 AM	DW	DPD
Chlorine:	3.0 mg/l	A	6/3/25 9:20 AM	DW	DPD
Turbidity:	1 NTU	A	6/3/25 9:20 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
PPS

Lab# 004

Customer

Facility Name: *Allerdice H.S.*

Address: *2409 Shady Ave.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *6/3/25*
Time: *9:20 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/6/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	6/4/25 11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	6/4/25 11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	A	6/3/25 5:15 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.4 SU	A	6/3/25 9:20 AM	DW	DPD
Chlorine:	3.0 mg/l	A	6/3/25 9:20 AM	DW	DPD
Turbidity:	1 NTU	A	6/3/25 9:20 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor