



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2523

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Facility Name:** Thorn Run Apts

**Sample Collection**

Date: 7/1/25

**Address:** 700 Lee Drive  
Coraopolis, PA 15108

Time: 11:45 AM

Method: Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

Date: 7/4/25

**Source Type:** Pool

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	11:45 AM	VH
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:45 AM	VH
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:45 AM	VH

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2523

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Facility Name:** Thorn Run Apts

**Sample Collection**

Date: 7/1/25

**Address:** 700 Lee Drive  
Coraopolis, PA 15108

Time: 11:45 AM

Method: Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

Date: 7/4/25

**Source Type:** Pool

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	11:45 AM	VH
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:45 AM	VH
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:45 AM	VH

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor