1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2331

Customer

Facility Name:	Magee	
Address:	745 Greenfield Ave.	
	Pittsburgh, PA 15217	
Matrix:	Recreational Water	
Source Type:	Deep End	

Sample Collection

Date:	7/1/25
Time:	10:50 AM
Method:	Grab

Sample Final Analysis

Date:	7/4/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	10:50 AM	WB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/1/25	10:50 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:50 AM	WB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2331

Customer

Facility Name:	Magee
Address:	745 Greenfield Ave.
	Pittsburgh, PA 15217
Matrix:	Recreational Water
Source Type:	Deep End

Sample Collection

Date:	7/1/25
Time:	10:50 AM
Method:	Grab

Sample Final Analysis

Date:	7/4/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	10:50 AM	WB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/1/25	10:50 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:50 AM	WB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor