



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 118

Customer

Facility Name: Hampton Inn
Address: 2805 Freeport Rd.
Pittsburgh, PA 15238

Sample Collection

Date: 10/14/25
Time: 6:37 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 10/17/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/15/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/15/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/14/25	3:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	10/14/25	6:37 AM	AMH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/14/25	6:37 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/14/25	6:37 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith