

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665

S-10

Lab ID No. 02-04041

Lab# 259

Laboratory Analysis Report

<u>Customer</u> Facility Name:

Providence Pointe

Address: 301 Kane Boulevard

Pittsburgh, PA 15243

Matrix:

Recreational Water

Source Type: Spa

Sample Collection

Date: Time: 6/2/25 12:26 PM

Method: Grab

Sample Final Analysis

Date: Time: 6/5/25 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25	12:00 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	12:26 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	12:26 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	12:26 PM	CW	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665

S-10

Lab ID No. 02-04041

Lab# 259

Laboratory Analysis Report

<u>Customer</u> Facility Name:

Providence Pointe

Address: 301 Kane Boulevard

Pittsburgh, PA 15243

Matrix:

Recreational Water

Source Type: Spa

Sample Collection

Date: Time: 6/2/25 12:26 PM

Method: Grab

Sample Final Analysis

Date: Time: 6/5/25 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25	12:00 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	12:26 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	12:26 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	12:26 PM	CW	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)