



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2114

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	Matrix:	Source Type:	<b><u>Sample Collection</u></b>		
				Date:	Time:	Method:
Clover Commons	600 Cloview Plum, PA 15239	Recreational Water	Pool	6/3/25	10:08 AM	Grab
<b><u>Sample Final Analysis</u></b>				Date:	Time:	Analyst:
				6/6/25	9:30 AM	AS

<b><u>Accredited Analysis</u></b>	<b><u>Results</u></b>	<b><u>Reporting limit</u></b>	<b><u>Incubation Date/Time</u></b>	<b><u>Analyst</u></b>	<b><u>Method</u></b>	
Escherichia Coli:	Absent	Absent	6/4/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	3:50 PM	AH	SM 9215B

<b><u>Field Analysis</u></b>	<b><u>Results</u></b>	<b><u>Reporting limit</u></b>	<b><u>Date/Time</u></b>	<b><u>Analyst</u></b>	<b><u>Method</u></b>	
pH:	7.8 SU	7.2 - 7.8 SU	6/3/25	10:08 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:08 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:08 AM	EH	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2114

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Address:	Matrix:	Source Type:	<b><u>Sample Collection</u></b>		
				Date:	Time:	Method:
Clover Commons	600 Cloview Plum, PA 15239	Recreational Water	Pool	6/3/25	10:08 AM	Grab
<b><u>Sample Final Analysis</u></b>				Date:	Time:	Analyst:
				6/6/25	9:30 AM	AS

<b><u>Accredited Analysis</u></b>	<b><u>Results</u></b>	<b><u>Reporting limit</u></b>	<b><u>Incubation Date/Time</u></b>	<b><u>Analyst</u></b>	<b><u>Method</u></b>	
Escherichia Coli:	Absent	Absent	6/4/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	3:50 PM	AH	SM 9215B

<b><u>Field Analysis</u></b>	<b><u>Results</u></b>	<b><u>Reporting limit</u></b>	<b><u>Date/Time</u></b>	<b><u>Analyst</u></b>	<b><u>Method</u></b>	
pH:	7.8 SU	7.2 - 7.8 SU	6/3/25	10:08 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:08 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:08 AM	EH	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor