



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2698

Customer

Facility Name: Highland House Tower

Address: 5700 Bunkerhill St
Pittsburgh, PA 15206

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/11/25

Time: 1:25 PM

Method: Grab

Sample Final Analysis

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	1:25 PM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/11/25	1:25 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	1:25 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2698

Customer

Facility Name: Highland House Tower

Address: 5700 Bunkerhill St
Pittsburgh, PA 15206

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/11/25

Time: 1:25 PM

Method: Grab

Sample Final Analysis

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	1:25 PM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/11/25	1:25 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	1:25 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor