



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2734

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Highland Village	Date:	7/8/25
Address:	1502 Highland Dr, Finleyville, PA 15332	Time:	1:05 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<b><u>Sample Final Analysis</u></b>	
		Date:	7/11/25
		Time:	9:00 AM
		Analyst:	AS

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:48 PM	AH	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.8 SU	7.2 - 7.8 SU	7/8/25	1:05 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/8/25	1:05 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	1:05 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 2

Lab# 2734

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Highland Village	Date:	7/8/25
Address:	1502 Highland Dr, Finleyville, PA 15332	Time:	1:05 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

		<b><u>Sample Final Analysis</u></b>	
		Date:	7/11/25
		Time:	9:00 AM
		Analyst:	AS

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	3:48 PM	AH	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.8 SU	7.2 - 7.8 SU	7/8/25	1:05 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/8/25	1:05 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	1:05 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor