



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 252**

**Customer**

**Facility Name:** *Perry Traditional Academy*

**Address:** *3875 Perrysville Ave.  
Pittsburgh, PA 15214*

**Matrix:** *Recreational Water*

**Source Type:** *Pool Deep*

**Sample Collection**

**Date:** *2/16/26*

**Time:** *12:54 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *2/18/26*

**Time:** *11:30 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	2/17/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	2/17/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	2/16/26	5:08 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	2/16/26	12:54 PM	MM	DPD
Chlorine:	3.0 mg/l	A	2/16/26	12:54 PM	MM	DPD
Turbidity:	1 NTU	A	2/16/26	12:54 PM	MM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)