



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
PPS

Lab# 004

Customer

Facility Name: *Allerdice H.S.*

Address: *2409 Shady Ave.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *2/9/26*
Time: *1:08 PM*
Method: *Grab*

Sample Final Analysis

Date: *2/12/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	2/10/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	2/10/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	2/9/26	5:20 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.6 SU	A	2/9/26	1:08 PM	MM	DPD
Chlorine:	3.0 mg/l	A	2/9/26	1:08 PM	MM	DPD
Turbidity:	1 NTU	FALSE	2/9/26	1:08 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)