Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 306

Customer

Facility Name:	*University of Pittsburgh*
Address:	*3501 Allequippa St.*
	Pittsburgh, PA 15260
Matrix:	*Recreational Water*
Source Type:	*Sm Pool Deep*

Sample Collection

Date:	*6/16/25*
Time:	12:05 PM
Method:	*Grab*

Sample Final Analysis

Date:	*6/19/25*
Time:	10:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	3:48 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/16/25	12:05 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/16/25	12:05 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	12:05 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

_____
Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 306

Customer

Facility Name:	*University of Pittsburgh*
Address:	*3501 Allequippa St.*
	Pittsburgh, PA 15260
Matrix:	*Recreational Water*
Source Type:	*Sm Pool Deep*

Sample Collection

Date:	*6/16/25*
Time:	12:05 PM
Method:	*Grab*

Sample Final Analysis

Date:	*6/19/25*
Time:	10:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	3:48 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/16/25	12:05 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/16/25	12:05 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	12:05 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor