



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2057**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 6/2/25*  
*Time: 4:40 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 6/5/25*  
*Time: 9:30 AM*  
*Analyst: AS*

*Facility Name: Brentwood Borough Pool*  
*Address: Park Dr.*  
*Pittsburgh, PA 15227*

*Matrix: Recreational Water*  
*Source Type: Shallow End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25 11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25 6:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/2/25 4:40 PM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25 4:40 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25 4:40 PM	DW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2057**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 6/2/25*  
*Time: 4:40 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 6/5/25*  
*Time: 9:30 AM*  
*Analyst: AS*

*Facility Name: Brentwood Borough Pool*  
*Address: Park Dr.*  
*Pittsburgh, PA 15227*

*Matrix: Recreational Water*  
*Source Type: Shallow End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25 11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25 6:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/2/25 4:40 PM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25 4:40 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25 4:40 PM	DW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor