

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 428

7/7/25

Sample Collection Customer

Facility Name: Upper St. Clair High School Date: Time:

3:15 PM Address: 1825 McLaughlin Run Rd. Method: Grab Upper St. Clair, PA 15241

Sample Final Analysis Matrix: Recreational Water Date: 7/10/25

Time: 9:30 AM Source Type: Lap Deep Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/8/25 10:50 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/8/25 EΒ 10:50 AM SM 9222B Standard plate count: 0/ml 200/ml 7/7/25 5:50 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 7/7/25 | 3:15 PM | AF | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/7/25 | 3:15 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 | 3:15 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 428

7/7/25

Sample Collection Customer

Facility Name: Upper St. Clair High School Date: Time:

3:15 PM Address: 1825 McLaughlin Run Rd. Method: Grab Upper St. Clair, PA 15241

Sample Final Analysis Matrix: Recreational Water Date: 7/10/25

Time: 9:30 AM Source Type: Lap Deep Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/8/25 10:50 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/8/25 EΒ 10:50 AM SM 9222B Standard plate count: 0/ml 200/ml 7/7/25 5:50 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 7/7/25 | 3:15 PM | AF | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/7/25 | 3:15 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 | 3:15 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor