

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665

Laboratory Analysis Report

C-10

Lab# 2257

Customer

Highland Park Club

Address:

Facility Name:

1001 N. Negley Ave.

Pittsburgh, PA 15206

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date:

8/18/25 1:10 PM

Time: Method:

Grab

Sample Final Analysis

Date:

8/21/25

Time:

9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	9:00 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	8/18/25	2:42 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/18/25	1:10 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/18/25	1:10 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	1:10 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor