

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2525

Customer American Pools Management

> 3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Torrent of Upper St. Clair

2565 Boyce Plaza Rd. Address:

Upper St. Clair, PA 15241

Recreational Water Matrix:

Source Type: Pool Sample Collection

Date: 8/11/25 Time: 2:46 PM Method:

Grab

Sample Final Analysis

Date: 8/14/25 9:00 AM Time: Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent 8/12/25 10:30 AM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 8/12/25 10:30 AM EΒ SM 9222B Standard plate count: 5:30 PM SL 0/ml 200/ml 8/11/25 SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/11/25	2:46 PM	AF	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	2:46 PM	AF	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	2:46 PM	AF	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2525

Customer American Pools Management

> 3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Torrent of Upper St. Clair

2565 Boyce Plaza Rd. Address:

Upper St. Clair, PA 15241

Recreational Water Matrix:

Source Type: Pool Sample Collection

Date: 8/11/25 Time: 2:46 PM Method:

Grab

Sample Final Analysis

Date: 8/14/25 9:00 AM Time: Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent 8/12/25 10:30 AM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 8/12/25 10:30 AM EΒ SM 9222B Standard plate count: 5:30 PM SL 0/ml 200/ml 8/11/25 SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/11/25	2:46 PM	AF	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	2:46 PM	AF	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	2:46 PM	AF	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor