



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 045

Customer

Facility Name: Carrick High School
Address: 125 Parkfield St.
Pittsburgh, PA 15210

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 7/8/25
Time: 2:45 PM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/9/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	7/9/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	A	7/8/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	7/8/25	2:45 PM	EJ	DPD
Chlorine:	4.0 mg/l	B	7/8/25	2:45 PM	EJ	DPD
Turbidity:	1 NTU	A	7/8/25	2:45 PM	EJ	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 045

Customer

Facility Name: Carrick High School
Address: 125 Parkfield St.
Pittsburgh, PA 15210

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 7/8/25
Time: 2:45 PM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/9/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	7/9/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	A	7/8/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	7/8/25	2:45 PM	EJ	DPD
Chlorine:	4.0 mg/l	B	7/8/25	2:45 PM	EJ	DPD
Turbidity:	1 NTU	A	7/8/25	2:45 PM	EJ	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor